

VOC Content Test Certificate

Wednesday 29th September 2021

Supplier: Acrylic Technologies Australia Pty Ltd (Unit 4, 128 Station Road, Seven Hills, NSW 2147 AUSTRALIA).

Sample Description: C-Coat Standard T250

Date Tested: September 2021 (Tested by FORAY Laboratories – NATA Accreditation 1231)

Test Method: ASTM D3960-05 Standard Practice for Determining Volatile Organic Compound (VOC) Content of Paints and Related Coatings. ASTM D3960 as detailed for paints as well as South Coast Air Quality Management District (SCAQMD) Rule 1168.

Test Data:


Specification Green Building Council of Australia Green Star Design & As Built V1.3-13.1.1B Green Star Interiors V1.3-12.1.1B	C-Coat Standard T250
Interior Wall and Ceiling Paint limit: ≤16 grams per liter	13 grams per Litre as VOC content per material
<i>We hereby certify that C-Coat Standard T250 product is below the VOC Content limits of chosen categories specified by Green Building Council of Australia, Green Star Design & As Built, and Green Star Interiors</i>	



Dr. Vyt Garnys
PhD, BSc(Hons) AIMM, ARACI, ISIAQ
ACA, AIRAH, FMA
Managing Director and Principal Consultant



Dr. Tuan Duong
PhD, BE (Chem. Eng.)
Senior Consultant



Dr Srikanth C. Srivatsa
PhD (Chemistry)
Consultant

V2109065